



# NIPPON KAIJI KYOKAI

## Certificate

Certificate No.  
TA21864E(R)

OF

### APPROVAL

Item	:	A-60 class bulkhead
Product name	:	Class A60 Bulkhead restricted SeaRox FB 6020 / SeaRox FB 6050
Specification	:	See the drawings in Annex.
Applicant	:	Rockwool International A/S Hovedgaden 584, DK-2640 Hedehusene, Denmark
Manufacturers	:	See Annex.
Testing standard	:	2010 FTP Code Annex 1 / Part 3
Test report	:	See Annex.
Limitation	:	See Annex.

THIS IS TO CERTIFY that the above type of products has been approved by Nippon Kaiji Kyokai with type approval No. 16FPA8DA, and that the products of the above type will be accepted for use onboard ships classed with the Society as complying with the relevant requirements of the Society's *Rules for the Survey and Construction of Steel Ships* and those of the *International Convention for the Safety of Life at Sea, 1974, as amended*, subject to conditional upon the manufacturers having a quality control system audited by a competent authority to ensure continuous compliance with the type approval conditions.

This certificate is valid until 14 February 2026.

Issued at Tokyo on 3 August 2021.

NIPPON KAIJI KYOKAI



Y. Takao

General Manager

Material and Equipment Department

NOTE: The design, construction and way of installation subject to attachments. Any significant changes to the product without our approval will result in this certificate becoming null and void.

Annex to the Certificate No. TA21864E(R)



1. Manufacturers

Rockwool A/S

Hovedgaden 501, 2640 Hedehusene, Denmark

Roxul Rockwool Insulation India Pvt. Ltd.

Plot Z/4, Dahej SEZ, Dahej, District Bharuch 392 130, Gujarat, India

2. Test report


Test laboratory : DBI – Danish Institute of Fire and Security Technology  
Jernholmen 12, 2650 Hvidovre, Copenhagen, Denmark

Report number : PGA10657

Date of issue : 3 April 2015

3. Limitation

Application is restricted to such cases where fire hazard can be identified as being from the insulated side only. The insulated side of the bulkhead is to be faced to the space where fire hazard is identified.



All measurements in mm


**ROCKWOOL®**

**TECHNICAL INSULATION**

Subject: A-60 Bulkhead restricted SeaRox FB 6020/ SeaRox FB 6050

Drawing No. 140-1

Date: 2015/07/02



All measurements are in mm

Dansk Brand- og sikringsteknisk Institut  
Sponsor: Rockwool BV  
Subject: A-Class Bulkhead, details

File No.: PGA10657  
Test date: 25-03-2015  
Enclosure: 1.2